

BRE Global

Notified Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

Certificate of constancy of performance,

0832-CPR-F1467

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

55000-885AMP XP95 Analogue Addressable Photoelectric Multisensor Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

AMPAC Technologies PTY Ltd

7 Ledger Road
Balcatta
6021
Australia

and produced in the manufacturing plant(s)

Apollo Fire Detectors Limited

36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 19 December 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 19 December 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR-F1467

Bases:

45681-209AMP XP95/Discovery Standard Deep Mounting Base
45681-210AMP XP95 Mounting Base

Note:

Certificated with Apollo XP95 and S90 digital communication protocols that have been configured for the XP95 multisensor detector in accordance with manufacturer's instructions.



P Halligan, Certification Manager
On behalf of BRE Global Limited
Date of issue: 19 December 2016
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.