

Date of Issue – 12 September 2018

APOLLO FIRE DETECTORS LTD
EU DECLARATION OF CONFORMITY

- Product models:
58200-975MAR
58200-976MAR
- Name and address of the manufacturer or his authorized representative:
Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, PO9 1JR, UK
- This declaration of conformity is issued under the sole responsibility of the manufacturer:
Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, PO9 1JR, UK
- Objects of the declaration:
58200-975MAR Discovery Marine Waterproof Manual Call Point
58200-976MAR Discovery Marine Waterproof Manual Call Point with Isolator
- The object of the declaration described above is in conformity with the relevant Community harmonization legislation:

2014/90/EU	Marine Equipment Directive
2014/30/EU	EMC Directive
2011/65/EU	Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)
- References to the relevant harmonized standards used or references to the specifications in relation to which conformity is declared:

SOLAS 74 Reg. II-2/7	
SOLAS 74 Reg. X/3	
IMO Res.MSC.98(73)-(FSS Code) 9	
Regulation 2018/773	
EN54-11:2001:	Fire detection and fire alarm systems - Part 11: Manual Call Points
EN54-17:2005:	Fire detection and fire alarm systems - Part 17: Short-circuit isolators
IEC 60092-504:2016:	Special features – Control and instrumentation
IEC 60533:2015:	Electrical and electronic installations on ships – Electromagnetic compatibility

v2

A HALMA COMPANY



Assessed to ISO 9001:2008
LPCB Cert No. 010

Certificate No. 010
See www.RedBookLive.com

Assessed to ISO 14001:2004
Certificate number EMS 010

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk


www.apollo-fire.co.uk
Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB339 055354

BS EN 61000-6-3: 2007+A1: 2011 Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments

BS EN 50130-4:2011+A1: 2014 Alarm systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

7. The MED EC Type Examination (Module B) certificates **MED 1800024 (58200-975MAR)** and **MED 1800025/M1 (58200-976MAR)** have been issued by Lloyd's Register, 71 Fenchurch Street, London EC3M 4BS, Notified Body Number 0038 and EC Production Quality Assurance (Module D) certification **11-SO792467-9-MED** has been issued by ABS Europe Ltd, ABS House, 1 Frying Pan Alley, London E1 7HR, Notified Body number 0729.

Signed for and on behalf of Apollo Fire Detectors, 36 Brookside Road, Havant, PO9 1JR, UK

Havant, 12.09.2018  Mr. Karl Westhead – Technical Director